

Weekly Construction Container Inspection Checklist

A practical internal baseline. Site risk assessment and applicable rules control the interval.

PROJECT

DATE

SITE LEAD

CONTAINER ID

PLACEMENT

☐	Approved bearing points remain stable
☐	Container does not rock or show new twist
☐	Frame remains level in both directions
☐	Drainage and door apron are clear
☐	Vegetation, mud and stored material do not block access

DOORS AND SECURITY

☐	Both doors operate without forcing
☐	Hinges, rods, cams and handles are intact
☐	Gaskets remain continuous
☐	Lockbox, lock and key control are functional

SHELL AND INTERIOR

☐	No new daylight, water marks or active corrosion
☐	Roof condition observed from an approved safe vantage point
☐	Vents remain open and unblocked
☐	Floor has no new soft, broken or contaminated areas
☐	Humidity or condensation issues recorded

OPERATIONS

☐	Interior aisle remains clear
☐	Shelving is stable and within posted load limits
☐	Electrical covers, cords and lighting are intact
☐	Fire extinguisher and emergency access are clear
☐	Corrective actions have an owner and due date

FIELD NOTE

Door binding can indicate shifting support or damage. Do not force the doors or stand in their travel path. Stop use if instability is suspected.